

**ICHALKARANJI TEXTILE DEVELOPMENT CLUSTER LTD.
ICHALKARANJI, DIST. KOLHAPUR.**

MINUTES OF PREBID MEETING HELD ON 11TH JULY 2007 AT 11.00 AM

Name of Work :

Providing, lowering, laying jointing of HDPE (High Density Polyethylene Pipe) and constructing Sump & Pump House and Pumping Machinery and Rising Main and allied works.

The points raised by parties and decisions taken by Ichalkaranji Textile Development Cluster Ltd. are as follows which shall be part & partial of the tender document.

Sr. No.	Points raised by parties	Decision taken by ITDC
1	Parties requested to consider the names of HDPE pipe manufacturers in addition to four manufacturers mentioned in tender document at Page No. 68.	It has been decided to consider M/s. Jain Irrigation System Ltd. Jalgaon & Parixit Industries Ltd. who have manufactured similar quality of pipes and used for effluent purpose as both the manufacturers are established for similar jobs.
2	Parties have requested to provide 75% advance against supply of pipes.	Ichalkaranji Textile Development Cluster has not considered the request.
3	Parties have requested to provide additional amount on account of damage due to underground water supply lines, drainage lines, electrical & telephone cables etc.	Damage occurred during execution due to water supply line and drainage shall be repaired by Ichalkaranji Textile Development Cluster Ltd. whereas damage due to electrical and telephone line etc shall be in the scope of tenderer.
4	Parties have suggested to consider RCC chamber in place of BB Masonry chamber as mentioned in the tender document.	Tenderer may quote rates on the basis of chamber specified in tender. Alternatively they may quote separate rates for RCC chambers considering their own designs.
5	Parties have suggested that CI sluice valves and air valves considered in the tender document shall be eroded due to acidic reaction stainless steel 304 shall be suitable.	Ichalkaranji Textile Development Cluster Ltd. has agreed for Stainless Steel 304 valves.
6	Parties have suggested to consider centrifugal pumps in place of submersible pumps.	Ichalkaranji Textile Development Cluster Ltd. has decided to consider submersible pumps as mentioned in tender document.
7	Parties have requested to refund 5% Security Deposit deducted from R.A. Bill on submission of Bank guarantee.	Ichalkaranji Textile Development Cluster Ltd. has agreed to release 5% S.D. after completion of Project on submission of performance Bank Guarantee from Nationalized Bank for the period of two years.